

CITY OF PROVIDENCE FIRE DEPARTMENT – VENDOR REGULATIONS

- Open flame or cooking is not permitted under tents; tents shall be weighted/secured down.
- Propane or any compressed gas shall be restrained/strapped/secured.
- No cooking under tents.
- First aid kit should be on site.
- Trip hazards shall be addressed/covered (rubber mats are acceptable).
- Electrical cords shall be rated for exterior use and of the correct gauge for equipment they serve.
- If a generator is used; **FUELING OF THE GENERATOR WHILE IT IS RUNNING is STRICTLY PROHIBITED,** and fuel shall be kept at a 5' minimum from generator plus a fire extinguisher (10lb or greater) shall be available.